



**Date** 3/23/2010 **Vessel** \_\_\_\_\_  
**Material** H1E1  
**State Pit Number** 49-065  
**Quarry** Cedarville  
**Sample from stockpile at** Bay Aggregate  
**Pile Location** Loading Face

Sieve Size	Retained Weight	Retained Percent	Cumulative % Retained	Cumulative % Passing	Specification Requirements
2 1/2 "					
2 "					
1 1/2 "	0	0.0%	0.0%	100%	
1 1/4 "					
1 "	0	0.0%	0.0%	100%	
3/4 "	0	0.0%	0.0%	100%	
1/2 "	0	0.0%	0.0%	100%	
3/8 "	0	0.0%	0.0%	100%	
no. 4	417	18.5%	18.5%	82%	
no. 8	1389	61.6%	80.1%	20%	
no. 16	342	15.2%	95.2%	5%	
no. 30	57	2.5%	97.8%	2%	
no. 50	19	0.9%	98.6%	1%	
no. 100	13	0.6%	99.2%	1%	
no. 200	15	0.6%	99.8%	0%	
pan	4	0.2%	100.0%	0%	
<b>TOTAL:</b>	<b>2254.70</b>	<b>100.00%</b>			

**LOSS BY WASH**

**LBW MAX**

Initial Weight  g  
 Weight after Washing  g  
 Loss by Washing  g

**MOISTURE**

Initial Weight  g  
 Dry Weight  g  
 Moisture  g

Tested By \_\_\_\_\_

L.Philippi  
 Michigan Certified Aggregate Technician  
 Cert # 101992-0213